


Forsyth County - Improvement Permit



Forsyth County
Division of Environmental Health
799 North Highland Avenue
Winston-Salem, NC 27102-0686
(336) 703-3225

PIN : 6940492195 Tax Lot No: 007 Tax Block No: 5128 File: 15916 - 1

NOTE TO INSPECTIONS DIVISION: The Improvement Permit may not be used to obtain a building permit. It will be necessary to make application to the Health Department for a Construction Authorization before a building permit may be issued.

If the information on the Improvement Permit is falsified, changed or the site altered, then the Improvement Permit shall become invalid.

Permit is Valid until : 06/24/2013

Applicant: Steven C. Ridenour
3577 NC 8 & 65 Hwy.

Owner: Alan Putman
275 Baker Rd.

Germanton, NC 27019

Winston Salem, NC 27107

Property: Off Baux Mountain Rd.

Directions to site:
Please call applicant before coming
336/499-3824

Germanton, NC 27019

Subdivision:

Facility Type:	<u>SINGLE FAMILY</u>	Evaluated for:	<u>NEW</u>
		System Type:	<u>50% REDUCTION</u>
Water Supply:	<u>NEW WELL</u>	Repair System Type:	<u>50% REDUCTION</u>
Saprolite System:	<u>YES</u> LTAR: <u>0.3000</u>	Projected Daily Flow:	<u>360</u> GPD

Every sanitary sewage treatment and disposal system shall be located at least the minimum horizontal distance from the following:

- Any private water supply source, including any well or spring-100 feet, Any building foundation - 5 feet
- Any basement-15 feet, Any property line - 10 feet, Top slope of embankments or cuts of 2 feet or more vertical height - 15 feet,
- Any swimming pool - 15 feet, Any other nitrification field (except repair area) - 20

PIN :6940492195

Tax Lot No:007

Tax Block No:5128

File : 15916 - 1

Property:Off Baux Mountain Rd.

Germanton, NC 27019

COMMENTS

40" Trench Depth

Improvement Permits shall be valid upon a showing satisfactory to this department that the site and soil conditions are unaltered, that the facility, design wastewater flow, and wastewater characteristics are not increased, and that a wastewater system can be installed that meets the permitting requirements in effect on the date the improvement

See site plan on attached sheet

Applicant/legal reps. Signature:

Hyman K. Rideman

Date:

6/26/2008

Issued by:

Daughtery, Patrick

Date of Issue: 6/24/2008

Authorized State Agent:

Patrick Daughtery

Forsyth County Department of Public Health

Improvement Permit




If the information on the Improvement Permit is falsified, changed or the site is altered, then the Improvement Permit shall become invalid.

Applicant's Name Steven C Bidenkov File# 15916 Application# 200860137
Site Address off Baux Mtn Rd Lot 007 Block 5128
Subdivision _____ Phase/Section _____
Directions to Site Go Baux Mtn on left after Dusty trail

EHS Name Patrick Dougherty Issued Date 6-24-08 Expiration 6-24-13

NOTE: A BUILDING PERMIT SHALL NOT BE ISSUED WITH THIS PERMIT. AN AUTHORIZATION TO CONSTRUCT MUST BE ISSUED FIRST.



* Detail Next Page *

Scale: 1"=400'