

Stephenson's Well Drilling, Inc.  
1158 Cash Road  
Creedmoor, NC 27522  
(919) 528-1679

**WELL CONSTRUCTION RECORD**

of Environment and Natural Resources- Division of Water Quality

CERTIFICATION # 2423

Jeff Stephenson • Jamie Stephenson • Dwight Stephenson

**STEPHENSON'S WELL DRILLING, INC**

Well Contractor Company Name

STREET ADDRESS 1158 CASH ROAD

CREEDMOOR NC 27522  
City or Town State Zip Code

(919) 528-1679  
Area code- Phone number

**2. WELL INFORMATION:**

SITE WELL ID #(if applicable)

STATE WELL PERMIT #(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply

DATE DRILLED 10-25-06

TIME COMPLETED 4 AM  PM

**3. WELL LOCATION:**

CITY: Oxford N.C., COUNTY: GRANVILLE  
7563 SAN HALL RD. 27565  
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

**TOPOGRAPHIC / LAND SETTING:**

Slope  Valley  Flat  Ridge  Other  
(check appropriate box)

LATITUDE 36° 25.319

LONGITUDE 078° 37.589

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source:  GPS  Topographic map  
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

**4. WELL OWNER**

OWNER'S NAME John Moyer

STREET ADDRESS 2101 Virginia Dare Pl.

Raleigh N.C. 27610

City or Town State Zip Code

(919) 266-0549

Area code - Phone number

**5. WELL DETAILS:**

a. TOTAL DEPTH: 145'

b. DOES WELL REPLACE EXISTING WELL? YES  NO

c. WATER LEVEL Below Top of Casing: 35 FT.  
(Use "X" if Above Top of Casing)

d. TOP OF CASING IS 1 FT. Above Land Surface  
\*Top of casing terminated at or below land surface may require a variance in accordance with 15A NCAC 2C .0118.

e. YIELD (gpm): 15 METHOD OF TEST gauge

f. DISINFECTION: Type HTH Amount 1 cup

g. WATER ZONES (depth):  
From 110' To 110' From To  
From To From To  
From To From To

6. CASING: Depth Diameter Thickness/Weight Material  
From 0 To 45 Ft. 6" 50 LB 21 POC  
From 45 To 48 Ft. 6" 188 galv.  
From To Ft.

7. GROUT: Depth Material Method  
From 0 To 20 Ft. concrete PAUK  
From To Ft.  
From To Ft.

8. SCREEN: Depth Diameter Slot Size Material  
From N/A To Ft. in. in.  
From To Ft. in. in.  
From To Ft. in. in.

9. SAND/GRAVEL PACK: Depth Size Material  
From N/A To Ft.  
From To Ft.  
From To Ft.

**10. DRILLING LOG**

From To Formation Description  
0' To 1' TOP SOIL  
1' To 15' RED. SOIL  
15' To 145' ROCK

**11. REMARKS:**

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Signature of Certified Well Contractor: James D. Stephenson, Sr. DATE: 10-25-06

PRINTED NAME OF PERSON CONSTRUCTING THE WELL: JAMES D. STEPHENSON, SR.