

**Ralph L. Hollowell, Jr.
150 Doll Harrell Road
Hertford, NC 27944**

Carolina Forestry
314W. Millbrook Rd.
Ste. 121
Raleigh, NC 27809

Re: Property located in Hertford County-between Old Hwy 13 and Hwy 13

This site was examined to determine if a sewage disposal system would be applicable. This letter is based on a preliminary evaluation-not acre by acre. Ralph Hollowell investigated the site and the following characteristics were found:

The site has no sloping topography, which is typical of the Coastal Plain. The soil information necessary to develop design criteria for any type of sewage disposal system must address the agronomic and engineering properties of the soil material. The information is gathered by literature such as the Soil Conservation Service and by examining the soil resources onsite. Also information has been used from the guidelines used by the State of North Carolina concerning Sewage Regulations. In support of this evaluation, soil profiles were examined by evaluating soil materials using a soil auger to a depth of 60 inches.

The site consisted of a Clay/Clay Loam soil over the entire area. Based on soil color, using the Munsell color chart the soil wetness was less than 36 inches. At a depth of 50 inches a fine to coarse grained sand was encountered

The following would be a suggestion for the types of systems:


- The property shall be graded in order to divert surface water from the site-(Turtle Back)
- The systems shall be located shallow placement with a minimum of 6 inches cover
- The lines shall be backfilled to a minimum of 5 feet with coarse grained sand
- Once system has been installed the site shall be seeded and landscaped

The Purchaser of property should contact Ralph Hollowell regarding any questions concerning the development of property

The findings presented herein represent Ralph Hollowell's professional opinion based on the site and soils evaluation and knowledge of the current laws and rules governing on-site wastewater systems in North Carolina.

Please feel free to contact me at 252-339-1416 if you have any questions or comments.

Sincerely,



Ralph L. Hollowell, Jr.
Environmental Health Specialist
License Soil Scientist

